

BUILDING MODIFICATIONS AND EXIT ACCESS



University buildings and systems may not be altered without the necessary permits and approvals.

MODIFICATIONS

Building modifications must be performed by personnel from UW Facilities, a contractor performing work under contract with the University or other approved means.

Please refer to the official [University Administrative Policy Statement 56.06 "Alterations to UW Seattle Campus Buildings and Grounds."](#)

FIRE DOORS

Fire doors must not be wedged or otherwise held open. If a fire door must be held open for operational purposes, an electromagnetic hold-open device connected to the building's fire alarm system should be used to allow automatic door closing in the event of an alarm.

EXIT ACCESS

Doors, gates and other access openings between spaces within buildings may not be modified or obstructed by equipment, storage or other materials without approval from EH&S's Building & Fire Safety team, Seattle Fire Department, and City of Seattle Department of Construction and Land Use.

Modifications to movable partitions and other furniture placement must not impede primary exit routes or widths.

DOOR HARDWARE

Door hardware is intended to meet specific fire and security needs and may not be modified without an approved design.

- Work requiring modification to door hardware should involve [UW Facilities Engineering Services](#).
- Locks must not be re-keyed without the knowledge and approval of the [UW Police Department](#).

Contact EH&S at 206.685.0341 or ehsdept@uw.edu for more information.